



## Current Sample

Customer: FINNING RICHMOND PWR SYSTEMS BR 14  
 Unit No: YALETOWN HOUSING  
 Model: PD6T\_NISSAN

Serial No: 50946  
 Compartment: FUEL : FUEL\_12464  
 Job Site: Default Site  
 Sampled Site:

## Details

Image/Altach	Lab Number	Eval	Sample Date	Sample Received	Meter Read	Oil Type	Oil Grade	Fluid Hrs	Fluid Add	Fluid Chg	Filter Chg
	N182-44045-6001	A	12 Feb 2014	14 Feb 2014	577			7	25.00	Y	Y

## Lubrication Results

Lab Number	Eval	Odor	V40	Appearance	KFW	API Gravity	Flash Point	Color
N182-44045-6001	A	Normal	1.9	Clear	0.01	38.9	58.0	Orange

## Element Results

Lab Number	Eval	Na	K	Si	Al	Fe	Zn	Ca	Mg	P	S
N182-44045-6001	A	0	<0	0	<0	0	<0	0	0	<0	76

## Interpretation Comments

Lab Number	Eval	Comments
N182-44045-6001	A	Sample conforms to standard diesel properties. Spectroanalysis does not detect any contamination. Fuel is fit for further use. Suggest resample again in 6 months if fuel has not been used up during that time.